



SLUTTDOKUMENTASJON

Pos nr	Menge	Enh.	Bestrrelse	Type	Data	Mont nr	Referanse
15	2	stk	Bjelke				E000-M-TD-74-0134
14	nødv		Kabelbro	Wibe KHZP			
13	nødv	stk	Kabelkammer				E000-M-TD-74-0109
12	4	stk	Isolator	Reliable (ENSTO NTP)			ENSTO NTP nr. K 33743 50
11	nødv	m	Al-line nr. 150	Halogenfri isolasjon	1 kV		
10	nødv	m	Kabel	TXSI 36 kV 1 x 400/35 mm ²			
9	4	stk	Al - bøyeklemme	Karl Pfisterer			El nr 28 715 52
8	1	stk	Støttesolator	Rebosio			
7	1	stk	Brakett for støttesolator				E000-M-TD-74-0135
6	4	stk	Kabelsko	Elpress AKK 400-16			El nr 20 430 62
5	2	stk	Kabelendemuffe	Elastimold 775LR/CS268	1250 A 4,15 kV		
4	2	stk	Kabelendemuffe	Raychem EPKT-36ETXQ	205W346		
3	3	stk	Tildeckingshette	Maxeta 331 993			El nr 28 742 32
2	2	stk	Transformator-klemme	Maxeta 331 993 993			El nr 28 742 28
1	1	stk	Sugetransformator	ABB Kraft 93 kVA	780/780 A 119/119 V		T2-403060

Rev	Dato	Endring - erstatning	Taget	Saksh	Sign
F01	08 02 00	Som bygget	FOR	FOR	ALA
NSB Gardermobanen A/S ABB Energi AS - kontrakt K-1839			Dato 08 02 00 Saksh FOR		
Kontrakt nr: Leverandør: ABB ABB Kraft AS			DAK nr:		
Avstand Oslo S: Leverandør tegn nr: 9BET010042-NAL			Skala: 1:50		
Dato:			Erstatt for:		
Tekst - beskrivelse:			Dato:		
ARRANGEMENT SUGETRANSFORMATOR I FJELLTUNNEL			000		
GNB tegn nr: E000-M-TH-74-0051			Rev: F01		
NSB tegn nr:			Rev:		